



ICC
EVALUATION
SERVICE

In Cooperation with



Most Widely Accepted and Trusted

ESR-2971

Reissued 05/2018

Revised 10/2018

This report is subject to renewal 05/2019.

ICC-ES Evaluation Report

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
SECTION: 07 25 00—WATER-RESISTIVE BARRIERS/WEATHER BARRIERS

REPORT HOLDER:

KB BUILDING PRODUCTS, LLC

EVALUATION SUBJECT:

**BREATHE EZ® HOUSEWRAP, BREATHE EZ® MPL HOUSEWRAP,
BREATHE EZ® MPH HOUSEWRAP, AND BREATHE EZ® EXTRA HOUSEWRAP**



“2014 Recipient of Prestigious Western States Seismic Policy Council (WSSPC) Award in Excellence”



ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.



Copyright © 2018 ICC Evaluation Service, LLC. All rights reserved.

ICC-ES Evaluation Report

ESR-2971

Reissued May 2018

Revised October 2018

This report is subject to renewal May 2019.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION

Section: 07 25 00—Water-Resistive Barriers/Weather Barriers

REPORT HOLDER:

KB BUILDING PRODUCTS, LLC

EVALUATION SUBJECT:

BREATHE EZ® HOUSEWRAP, BREATHE EZ® MPL HOUSEWRAP, BREATHE EZ® MPH HOUSEWRAP, AND BREATHE EZ® EXTRA HOUSEWRAP

1.0 EVALUATION SCOPE

1.1 Compliance with the following codes:

- 2015, 2012, 2009 and 2006 *International Building Code*® (IBC)
- 2015, 2012, 2009 and 2006 *International Residential Code*® (IRC)
- 2015, 2012, 2009 and 2006 *International Energy Conservation Code*® (IECC)
- 2013 *Abu Dhabi International Building Code* (ADIBC)[†]

[†]The ADIBC is based on the 2009 IBC. 2009 IBC code sections referenced in this report are the same sections in the ADIBC.

Properties evaluated:

- Water resistance
- Surface-burning characteristics
- Air Barrier

1.2 Evaluation to the following green code(s) and/or standards:

- 2016 California Green Building Standards Code (CALGreen), Title 24, Part 11
- 2015 and 2012 *International Green Construction Code*® (IgCC)
- 2014 and 2011 ANSI/ASHRAE/USGBC/IES Standard 189.1—Standard for the Design of High-Performance Green Buildings, Except Low-Rise Residential Buildings
- 2015, 2012 and 2008 ICC 700 *National Green Building Standard*™ (ICC 700-2015, ICC 700-2012 and ICC 700-2008)

Attributes verified:

- See Section 2.0.

2.0 USES

The products described in this report are used as water-resistive barriers on the exterior side of exterior walls of buildings of any construction type under the IBC and construction permitted under the IRC. They are equivalent to Grade D paper as described in 2012, 2009 and 2006 IBC Section 2510.6 and IRC Section R703.6.3, with a 60-minute water-resistance rating. The products may be used as an air barrier material under IRC Section N1102.4.1, 2015 IECC Sections C402.5 and R402.4, 2012 IECC Sections C402.4 and R402.4, and 2009 and 2006 IECC Sections 402.4 and 502.4; and in an air barrier assembly under 2015 IECC Section C402.5.1.2.2 and 2012 IECC Section C402.4.1.2.2.

The attributes of the water-resistive barriers have been verified as conforming to the provisions of (i) CALGreen Section 5.407.1 for water-resistive barriers and Section A4.407.5 for air barriers; (ii) 2012 and 2015 IgCC Section 605.1.2.1 for air barriers; (iii) 2014 ASHRAE 189.1 Section 7.3.1.1 and 2011 ASHRAE 189.1 Section 7.4.2.9 for air barriers; (iv) ICC 700-2015 Section 602.1.8, 11.602.1.8 and 12.6.602.1.8; (v) ICC 700-2012 Section 602.1.8, 11.602.1.8 and 12.5.602.1.8; and (vi) ICC 700-2008 Section 602.9 for water-resistive barriers. Note that decisions on compliance for those areas rest with the user of this report. The user is advised of the project-specific provisions that may be contingent upon meeting specific conditions, and the verification of those conditions is outside the scope of this report. These codes or standards often provide supplemental information as guidance.

3.0 DESCRIPTION

3.1 Breathe EZ® Housewrap:

This product consists of a woven, microperforated, polyolefin fabric with an additional polyolefin coating, and is available in various colors. The finished product has a nominal basis weight of 65 grams per square meter and is produced in rolls of varying sizes.

The product has a flame spread index of less than 25 and a smoke-developed index of less than 450, when tested in accordance of ASTM E84.

When tested in accordance with ASTM E2357, the air barrier assembly described in Section 4.2 of this report incorporating the Breathe EZ® Housewrap has an air leakage rate not exceeding 0.02 L/s/m² at 75 Pa [0.004 cfm/ft² at 0.3 w.g. (1.57 psf)] in accordance with 2015 IECC Section C402.5.1.2.2 and 2012 IECC Section C402.4.1.2.2.

3.2 Breathe EZ[®] MPL Housewrap and Breathe EZ[®] MPH Housewrap:

These products consist of a nonwoven, microporous polyolefin fabric and membrane and are available in various colors. The finished product is available in low-perm (MPL) and high-perm (MPH) versions. The products are produced in rolls of varying sizes.

These products have a flame spread index of less than 25 and a smoke-developed index of less than 450, when tested in accordance of ASTM E84.

The products have an air leakage rate not exceeding 0.02 L/s/m² at 75 Pa [0.004 cfm/ft² at 0.3 w.g. (1.57 psf)] when used as an air barrier material under IRC Section N1102.4.1 and IECC Section 402.4 or 502.

3.3 Breathe EZ[®] Extra Housewrap:

This product comprises a cross-woven polypropylene fabric and nonperforated breathable barrier layer, including stabilizing agents for ultraviolet light and thermal cycling. The finished product is produced in rolls of varying sizes.

The product has a flame spread index of 25 or less and a smoke-developed index of 450 or less, when tested in accordance with ASTM E84.

Breathe EZ[®] Extra Housewrap has an air leakage rate not exceeding 0.02 L/s/m² at 75 Pa [0.004 cfm/ft² at 0.3 w.g. (1.57 psf)] when used as an air barrier material under IRC Section N1102.4.1 and IECC Section 402.4 or 502.

4.0 INSTALLATION

4.1 General:

The water-resistive barriers described in this report are installed after wall framing is completed, and before or after windows and doors are installed. The roll is placed approximately 6 inches (152 mm) from the starting corner and is fastened to the sheathing with corrosion-resistant staples with minimum 1-inch (25.4 mm) crowns, corrosion-resistant nails having minimum ³/₈-inch-diameter (9.5 mm) heads, or corrosion-resistant nails having 1-inch-diameter (25.4 mm) plastic washer heads, spaced at a minimum of 6 inches (152 mm) vertically; and is then unrolled around the building and fastened with nails or staples spaced between 16 and 24 inches (406 to 609 mm) on center at top and bottom sill plates and at framing members, and no more than 24 inches (609 mm) on center in the field. The printed side of the barrier is installed facing the outside. A minimum of 6 inches (152 mm) of overlap is to be provided for vertical seams and 2 inches (51 mm) for horizontal seams, except where the manufacturer's installation instructions specify a greater overlap dimension. When use is over wood-based sheathing in exterior plaster applications, two layers of Grade D water-resistive barrier with a 60-minute water-resistive rating must be applied over sheathing in accordance with 2012, 2009 and 2006 IBC Section 2510.6 or IRC Section R703.6.3. For cementitious coatings or exterior insulation and finish systems, application is to be in accordance with the evaluation report on the exterior coating.

The manufacturer's published installation instructions and this report are to be strictly adhered to. If requested by the code official, a copy of this report is to be available at the jobsite during installation.

4.2 Air Barrier Assembly:

When Breathe EZ[®] Housewrap is used as a component of an air barrier assembly, the water-resistive barrier must be

attached to the exterior side sheathing with fasteners specified in the manufacturer's published installation instructions. Seams in the water-resistive barrier must be sealed with 1⁷/₈-inch (47.6 mm) width KB Building Products LLC's Breathe EZ[®] Seaming Tape or equivalent pressure-sensitive tape. Minimum 1¹/₂-inch-thick (12.7 mm) gypsum wallboard on the interior side of the assembly must be attached to the wall framing per prescribed code provisions, with all the joints taped and sealed with joint compound. Penetrations in the air barrier assembly must be sealed in accordance with 2015 IECC Section C402.5.1.1(3) and 2012 IECC Section C402.4.2.

5.0 CONDITIONS OF USE

The water-resistive barriers described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 The water-resistive barriers must be installed in accordance with the manufacturer's published installation instructions, the requirements of the applicable code and this report. In the event of a conflict between this report and the manufacturer's published installation instructions, this report governs.
- 5.2 The water-resistive barriers must be covered by an exterior wall finish complying with the requirements of the applicable code.
- 5.3 Use of the water-resistive barriers as a means for drainage has not been evaluated and is outside the scope of this report.
- 5.4 Under the 2015 and 2012 IBC, installation on exterior walls on buildings of Type I, II, III or IV construction is limited to buildings that are not greater than 40 feet in height above grade plane.
- 5.5 The products are under a quality control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

- 6.1 Data in accordance with the ICC-ES Acceptance Criteria for Water-resistive Barriers (AC38), dated August 2016 (editorially revised April 2018).
- 6.2 Report of testing in accordance with ASTM E84.
- 6.3 Reports of testing in accordance with ASTM E2178.
- 6.4 Reports of testing in accordance with ASTM E2357.

7.0 IDENTIFICATION

- 7.1 The products described in this report are identified by a label on the container of each roll of membrane and by printing on the product, with the name, address and telephone number of KB Building Products, LLC, the product name, and the evaluation report number (ESR-2971).
- 7.2 The report holder's contact information is the following:

**13540 EAST BOUNDARY ROAD
BUILDING 1, SUITE 102
MIDLOTHIAN, VIRGINIA 23112-3943
(804) 744-7253
www.kb-bp.com**